

SALES SPECIFICATION

50% Caustic Soda Membrane West Coast

<u>Property</u>	<u>Minimum</u>	<u>Maximum</u>
Total Alkalinity as Na ₂ O (wt. %)	37.50	39.50
Hydroxide Alkalinity as NaOH (wt. %)	48.50	51.00
Sodium Carbonate as Na ₂ CO ₃ (wt. %)		0.15
Sodium Chloride as NaCl (ppm by wt.)		100
Sodium Chlorate as NaClO ₃ (ppm by wt.)		40
Sodium Sulfate as Na ₂ SO ₄ (ppm by wt.)		30
Iron as Fe (ppm by wt.)		3.0
Copper as Cu (ppm by wt.)		0.50
Nickel as Ni (ppm by wt.)		0.50

Meets ANSI/AWWA B501-08 test requirements.

Meets ASTM E1098-93 Type A and B test requirements.

Meets Food Chemicals Codex (FCC) test requirements.

EC-CS-48 7/03