



## Sodium Chlorite CT Value Ranges for Inactivation of Various Microorganisms

Table 1 is a summary of CT value ranges for the inactivation of various microorganisms by different disinfectants. This table is a compilation of reported CT values taken from various published sources.

CT is defined as disinfectant contact time, the mathematical product of C x T, where C is the residual disinfectant concentration measured in mg/L, and T is the corresponding contact time measured in minutes.

All CT values are for 99% inactivation at 5°C except for *Giardia lamblia* and *Cryptosporidium parvum*.

### Further Information

More detailed information on sodium chlorite is available on request through the OxyChem Technical Service Department. Call or write to:

OxyChem  
Technical Service Department  
Post Office Box 12283  
Wichita, Kansas 67277-2283  
800-733-1165 option #1  
[www.oxy.com](http://www.oxy.com)

Microorganism	Disinfectant			
	Free Chlorine pH 6 to 7	Preformed Chloramine pH 8 to 9	Chlorine Dioxide pH 6 to 7	Ozone pH 6 to 7
<i>Escherichia Coli</i>	0.034 - 0.05	95 - 180	0.4 - 0.75	0.02
Polio 1	1.1 - 2.5	768 - 3740	0.2 - 6.7	0.1 - 0.2
Rotavirus	0.01 - 0.05	3806 - 6476	0.2 - 2.1	0.006 - 0.06
<i>Giardia lamblia</i> cysts	47 > 150	2200(a)	26(a)	0.5 - 0.6
<i>Giardia muris</i> cysts	30 - 630	1400.00	7.2 - 18.5	1.8 - 2.0
<i>Cryptosporidium parvum</i>	7200(b)	7200(c)	78(c)	5 - 10(b)

(a) Values for 99% inactivation at pH 6-9.

(b) 99% inactivation at pH 7 and 25°C

(c) 90% inactivation at pH 7 and 25°C

600-204 Sodium Chlorite 08/2018



### REFERENCES

1. Aieta, E. M. and Berg, J. D., "A Review of Chlorine Dioxide in Drinking Water Treatment", Journal of American Water Works Association, 78, 62, 1986.
2. National Interim Primary Drinking Water Regulations; Control of Trihalomethanes in Drinking Water; Final Rule, Vol. 44, No. 231, November 29, 1979.
3. Trihalomethane in Drinking Water, Sampling; Analysis, Monitoring and Compliance, U.S. Environmental Protection Agency, EPA 570/9-83-002, August 1983.
4. Drinking Water; National Primary Drinking Water Regulations; Filtration, Disinfection; Turbidity, Giardia lamblia, Viruses, Legionella, and Heterotrophic Bacteria; Final Rule, Federal Register, June 28, 1989.
5. Symons, J. M., et al., "Treatment Techniques for Controlling Trihalomethanes in Drinking Water", U.S. Environmental Protection Agency, EPA 600/2-81-156, 1981.
6. Rice, R. G. and Gomez-Taylor, M., "Occurrence of By-Products of Strong Oxidants Reacting With Drinking Water Contaminants - Scope of the Problem, Environmental Health Perspectives, 69,31-44, 1986.
7. Lykins, Jr., B. W. et al., "Chemical, Microbiological, and Mutagenic Effects of Using Alternative Disinfectants for Drinking Water Treatment", proceedings of 42nd Environmental Engineering Conference, University of Kansas, February 5, 1992.
8. Lykins, Jr., B. W. and Griese, M. H., "Using Chlorine Dioxide for Trihalomethane Control", Journal American Water Works Association, 78, 88, 1986.
9. Griese, M. H. et al., "The Use of Reducing Agents For the Total Elimination of Chlorine Dioxide and Chlorite Residuals in Drinking Water", Journal of American Water Works Association, 83, 55-61, 1991.
10. Code of Federal Regulations, 40 CFR 141.2

600-204 Sodium Chlorite 08/2018



14555 Dallas Parkway, Suite 400  
Dallas, TX 75254  
800-752-5151

**Important: The information presented herein, while not guaranteed, was prepared by technical personnel and is true and accurate to the best of our knowledge. NO WARRANTY OF MERCHANTABILITY OR OF FITNESS FOR A PARTICULAR PURPOSE, OR WARRANTY OR GUARANTY OF ANY OTHER KIND, EXPRESS OR IMPLIED, IS MADE REGARDING PERFORMANCE, SAFETY, SUITABILITY, STABILITY OR OTHERWISE. This information is not intended to be all-inclusive as to the manner and conditions of use, handling, storage, disposal and other factors that may involve other or additional legal, environmental, safety or performance considerations, and Occidental Chemical Corporation assumes no liability whatsoever for the use of or reliance upon this information. While our technical personnel will be happy to respond to questions, safe handling and use of the product remains the responsibility of the customer. No suggestions for use are intended as, and nothing herein shall be construed as, a recommendation to infringe any existing patents or to violate any Federal, State, local or foreign laws.**