

Sodium Chlorite

Certification of Water Treatment Chemicals

NSF/ANSI Standard 60

Background

For many years state regulatory agencies have been concerned about health effects from water treatment chemicals. Most states did not have the expertise to review and evaluate the health effects of additives and relied upon third parties to do so. These third parties have included the federal EPA and FDA, as well as the National Sanitation Foundation (NSF). Approvals or certifications by these parties were neither stringent nor widespread. Many products used in the treatment of drinking water never received formal evaluation.

In recent years, the public has demanded a more complete evaluation of water additives and their potential to cause acute and chronic health effects. It became clear that a more formal third-party evaluation would be necessary to meet the growing public concerns regarding health effects. These concerns prompted Congress, EPA and states to expand their evaluation programs relating to potential health effects resulting from chemicals in drinking water.

In 1984, the EPA requested proposals from the private sector to develop voluntary consensus standards for drinking water additives. The following year, the EPA awarded the contract for the development of the additives program to an NSF led drinking water industry consortium. Members of this consortium included the AWWA Research Foundation, the Association of State Drinking Water Administrators (ASDWA), and American Water Works Association (AWWA).

The first standard for direct additives, *ANSI/NSF Standard 60: Drinking Water Treatment Chemicals-Health Effects* was adopted by NSF in December

1987. This standard sets health effects criteria for all chemical additives in water treatment. Later, *ANSI/NSF Standard 61: Drinking Water System Components - Health Effects* was developed to cover indirect additives. Both standards have been adopted by the American National Standards Institute (ANSI). These standards and subsequent product certification have replaced the EPA Additives Advisory Program for drinking water additives and materials.

Product Certification

Many state and local regulatory agencies now require that products intended for use in drinking water be certified, by a third-party certifier, to be in compliance with ANSI/NSF Standard 60. The certification process requires testing and facility audits to verify compliance with the standard.

Since the certification process includes production facility audits, certification of products to ANSI/NSF Standard 60 is site specific. Certification of products repackaged or handled at other locations, or by distributors requires additional authorization from the certifying agency.

OxyChem has selected NSF International as its third-party certifier. The OxyChem sodium chlorite products and plant locations certified by NSF appear in *NSF Listings, Drinking Water Additives-Health Effects*, published three times annually by NSF. These listings are also available on the NSF Electronic Listings database at [Listing Category Search Page | NSF International](#). A summary of these listings for OxyChem products appears in Table 1.





Sodium Chlorite Certification of Water Treatment Chemicals NSF/ANSI Standard 60

TABLE 1 OxyChem NSF Certification Status ANSI/NSF Standard 60		
PLANT	PRODUCT	**MAX USE
Wichita, KS	Chlorine	30 mg/L
	Sodium Hydroxide Liquid	200 mg/L
	HCl - Burner Production	40 mg/L
	Akta Klor 7.5	87 mg/L
	Akta Klor 25	22 mg/L
	Technical Sodium Chlorite Solution 18.75	35 mg/L
	Technical Sodium Chlorite Solution 31.25	22 mg/L
	31% Active Sodium Chlorite Solution	22 mg/L
Fairmont City, IL	Technical Sodium Chlorite Solution 50	14 mg/L
	Technical Sodium Chlorite Dry	7 mg/L
	Akta Klor 7.5	87 mg/L
	Akta Klor 25	22 mg/L
	Technical Sodium Chlorite Solution 18.75	35 mg/L
Sauget, IL	Technical Sodium Chlorite Solution 31.25	22 mg/L
	31% Active Sodium Chlorite Solution	22 mg/L
	Technical Sodium Chlorite Solution 50	14 mg/L
	Technical Sodium Chlorite Dry	7 mg/L
** Max Use: The maximum use limit (MUL) is the maximum concentration of a direct additive that is acceptable under the NSF Drinking Water Standard 60.		

Further Information

More detailed information on sodium chlorite is available upon request through the OxyChem Technical Service Department. Call or write to:

OxyChem Technical Service Department
6200 S. Ridge Rd.
Wichita, Kansas 67215
800-733-1166 opt 1
OxyChem_Tech_Service@oxy.com

600-203 Sodium Chlorite 04/2022



Wichita Technical Service Department
6200 South Ridge Road, Wichita, KS 67215
Tel: 800-733-1165 ext. 1
OxyChem_Tech_Service@oxy.com

Important: The information presented herein, while not guaranteed, was prepared by technical personnel and is true and accurate to the best of our knowledge. NO WARRANTY OF MERCHANTABILITY OR OF FITNESS FOR A PARTICULAR PURPOSE, OR WARRANTY OR GUARANTY OF ANY OTHER KIND, EXPRESS OR IMPLIED, IS MADE REGARDING PERFORMANCE, SAFETY, SUITABILITY, STABILITY OR OTHERWISE. This information is not intended to be all-inclusive as to the manner and conditions of use, handling, storage, disposal, and other factors that may involve other or additional legal, environmental, safety or performance considerations, and Occidental Chemical Corporation assumes no liability whatsoever for the use of or reliance upon this information. While our technical personnel will be happy to respond to questions, safe handling and use of the product remains the responsibility of the customer. No suggestions for use are intended as, and nothing herein shall be construed as, a recommendation to infringe any existing patents or to violate any Federal, State, local or foreign laws.